

oil. Benzene has not been found to be mutagenic in bacterial assays, but it has been shown to cause chromosomal aberrations in vivo in a number of species, including humans, and to be positive in the mouse micronucleus test.

Beryllium

The primary source of beryllium compounds in water appears to be release from coal burning and other industries using beryllium. Other sources of beryllium in surface water include deposition of atmospheric beryllium and weathering of rocks and soils containing beryllium. Beryllium is not likely to be found in natural water above trace levels as a result of the insolubility of beryllium oxides and hydroxides in the normal pH range.

Reason for not establishing a guideline value	Rarely found in drinking-water at concentrations of health concern
Assessment date	2009
Principal references	IPCS (2001) <i>Beryllium and beryllium compounds</i> WHO (2009) <i>Beryllium in drinking-water</i>

As beryllium is rarely, if ever, found in drinking-water at concentrations of concern, it is not considered necessary to set a formal guideline value.

A health-based value for beryllium in drinking-water of 12 µg/l can be calculated based on an allocation of 20% of the TDI of 2 µg/kg body weight, derived from a long-term study in which dogs exhibited lesions of the small intestine, to drinking-water and assuming a 60 kg adult drinking 2 litres of water per day. This allocation is probably conservative, as the limited data on food indicate that exposure from this source is likely to be well below the TDI.

Although beryllium appears to be found in drinking-water sources and drinking-water at low concentrations, the database on occurrence is limited, and there may be specific circumstances in which concentrations can be elevated due to natural sources where the pH is either below 5 or above 8 or there is high turbidity.

Boron

Boron compounds are used in the manufacture of glass, soaps and detergents and as flame retardants. Naturally occurring boron is present in groundwater primarily as a result of leaching from rocks and soils containing borates and borosilicates. The borate content of surface water can be increased as a result of wastewater discharges, but this use has decreased significantly, and levels of boron in wastewater discharges continue to fall.

Guideline value	2.4 mg/l (2400 µg/l)
Occurrence	Concentrations vary widely and depend on the surrounding geology and wastewater discharges; for most of the world, the concentration of boron in drinking-water is judged to be below 0.5 mg/l