

In experimental animals, prolonged exposure in the diet causes liver damage. Chlordane produces liver tumours in mice, but the weight of evidence indicates that it is not genotoxic. Chlordane can interfere with cell communication in vitro, a characteristic of many tumour promoters. IARC re-evaluated chlordane in 1991 and concluded that there is inadequate evidence for its carcinogenicity in humans and sufficient evidence for its carcinogenicity in animals, classifying it in Group 2B.

Chloride

Chloride in drinking-water originates from natural sources, sewage and industrial effluents, urban runoff containing de-icing salt and saline intrusion.

The main source of human exposure to chloride is the addition of salt to food, and the intake from this source is usually greatly in excess of that from drinking-water.

Reason for not establishing a guideline value	Not of health concern at levels found in drinking-water
Additional comments	May affect acceptability of drinking-water
Assessment date	1993
Principal reference	WHO (2003) <i>Chloride in drinking-water</i>

Excessive chloride concentrations increase rates of corrosion of metals in the distribution system, depending on the alkalinity of the water. This can lead to increased concentrations of metals in the supply.

No health-based guideline value is proposed for chloride in drinking-water. However, chloride concentrations in excess of about 250 mg/l can give rise to detectable taste in water (see [chapter 10](#)).

Chlorine

Chlorine is produced in large amounts and widely used both industrially and domestically as an important disinfectant and bleach. In particular, it is widely used in the disinfection of swimming pools and is the most commonly used disinfectant and oxidant in drinking-water treatment. In water, chlorine reacts to form hypochlorous acid and hypochlorites. Concentrations of chlorate and some perchlorates increase in hypochlorite solutions upon storage at high ambient temperatures or when new hypochlorite is added to old hypochlorite.

Guideline value	5 mg/l (5000 µg/l) for free chlorine
Occurrence	Present in most disinfected drinking-water at concentrations of 0.2–1 mg/l
TDI	150 µg/kg body weight, derived from a NOAEL for the absence of toxicity in rodents ingesting chlorine in drinking-water for 2 years
Limit of detection	0.01 µg/l following pre-column derivatization to 4-bromoacetanilide by HPLC; 10 µg/l as free chlorine by colorimetry; 200 µg/l by ion chromatography

Treatment performance	It is possible to reduce the concentration of chlorine effectively to zero (< 0.1 mg/l) by reduction. However, it is normal practice to supply water with a chlorine residual of a few tenths of a milligram per litre to provide some protection against microbial recontamination and limit microbial growth problems during distribution.
Guideline value derivation	• allocation to water 100% of TDI • weight 60 kg adult • consumption 2 litres/day
Additional comments	The guideline value is conservative, as no adverse effect level was identified in the critical study. Most individuals are able to taste chlorine at the guideline value.
Assessment date	1993
Principal reference	WHO (2003) <i>Chlorine in drinking-water</i>

In humans and experimental animals exposed to chlorine in drinking-water, no specific adverse treatment-related effects have been observed. IARC has classified hypochlorite in Group 3 (not classifiable as to its carcinogenicity to humans).

Chlorine dioxide, chlorite and chlorate

Chlorite and chlorate are DBPs resulting from the use of chlorine dioxide as a disinfectant and for odour and taste control in water. Sodium chlorite and sodium chlorate are both used in the production of chlorine dioxide as well as for other commercial purposes. Chlorite and chlorate are also formed during the decomposition of hypochlorite solutions that are stored for long periods, particularly at warm temperatures. Where hypochlorite or chlorine dioxide is used as a disinfectant, the major route of environmental exposure to chlorite and chlorate is expected to be through drinking-water.

Provisional guideline values	<i>Chlorite</i>: 0.7 mg/l (700 µg/l) <i>Chlorate</i>: 0.7 mg/l (700 µg/l) The guideline values for chlorite and chlorate are designated as provisional because use of aged hypochlorite or of chlorine dioxide as disinfectants may result in the chlorite and chlorate guideline values being exceeded, and difficulties in meeting the guideline values must never be a reason for compromising adequate disinfection
Occurrence	When chlorine dioxide is used as the final disinfectant at typical doses, the resulting chlorite concentration would normally be less than 0.2 mg/l. Chlorate concentrations above 1 mg/l have been reported when hypochlorite was used, but such high concentrations would be unusual unless hypochlorite is stored under adverse conditions.
ADIs	<i>Chlorite</i> : 0–0.03 mg/kg bw based on a NOAEL of 3 mg/kg bw per day for reduced liver weight of F ₀ females and F ₁ males and females in a two-generation reproductive toxicity study in rats and using a safety factor of 100 (10 each for interspecies and intraspecies variability)